

OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 419 - Public Drinking Water Equipment Performance - Filtration

This is the Official Listing recorded on January 16, 2018.

Scinor Water America, LLC 16 Mallard Cove Centerport, NY 11721 631-708-9588

Facility: Beijing Scinor Membrane Technology Co., Ltd., China

Ultrafiltration	Devices			
SMT600-P23 [1]	SMT600-P38 ^[1]	SMT600-P50 [2]	SMT600-P51 ^[2]	SMT600-P52 [2]
SMT600-P53 [2]	SMT600-P55 [2]	SMT600-P56 ^[2]	SMT600-P57 ^[2]	SMT600-P60 [2]
SMT600-P72 [2]	SMT600-P80 ^[2]	SMT600-P81 ^[2]	SMT600-S26 ^[3]	SMT600-S40 ^[3]
SMT600-S48 [3]	SMT600-S51 ^[3]	SMT600-S60 ^[3]		

- [1] Certified by NSF for Cryptosporidium removal efficiency, with a mean log removal value (LRV) of 6.25 log, and a minimum LRV of 6.08 log. The maximum certified filtrate flux rate is 120 gfd. Also tested 2/22/2016 for virus removal efficiency, with a mean LRV of 4.34 and a minimum LRV of 2.69 log.
- [2] Certified by NSF for Cryptosporidium removal efficiency, with a mean log removal value (LRV) of 6.36 log, and a minimum LRV of 6.26 log. The maximum certified filtrate flux rate is 120 gfd. Also tested 5/1/2015 for virus removal efficiency, with a mean LRV of 5.14 and a minimum LRV of 3.98 log.
- [3] Certified by NSF for Cryptosporidium removal efficiency, with a mean log removal value (LRV) of 6.37 log, and a minimum LRV of 6.19 log. The maximum certified filtrate flux rate is 120 gfd. Also tested 2/22/2016 for virus removal efficiency, with a mean LRV of 4.37 and a minimum LRV of 3.63 log.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.

1 of 1